



Certificate of Compliance

Certificate: 2573800

Master Contract: 248705

Project: 80146398

Date Issued: 2023-01-23

Issued To: Profire Energy, Inc.
9671 283 Street
Acheson, Alberta, T7X 6J5
Canada

Attention: Ryan Northcott

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Junlong Pan
Junlong Pan

PRODUCTS

CLASS - C9098 01 - MISCELLANEOUS For Hazardous Locations

CLASS - C9098 81 - MISCELLANEOUS For Hazardous Locations - Certified to US Standards

Class I, Division 2, Groups A, B, C and D; Type 4

Profire 1300 Flare Ignition System (PF1300/PF1300F)

Model 1PS13-SC000:

Input: 12-24V, 5A Max
Temperature: -40°C to +80°C
Temp Code: T4A

Model 1PS13-SCB00:

Solar Panel Input: 12V Nominal (Solar Panel), 40W Max
Battery: 12V, 9Ah, AGM
Temperature: -40°C to +50°C
Temp Code: T5



Certificate: 2573800
Project: 80146398

Master Contract: 248705
Date Issued: 2023-01-23

APPLICABLE REQUIREMENTS

CSA C22.2 No. 94-M91	Special Purpose Enclosures
CSA C22.2 No. 142-M1987	Process Control Equipment
CSA C22.2 No. 213-M1987	Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
ANSI/UL 508-2013 <i>Seventeenth Edition</i>	Industrial Control Equipment
UL 50 11 th Edition	Enclosures for Electrical Equipment
ANSI/ISA 12.12.01 - 2012	Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Division 1 and 2 Hazardous (Classified) Locations

MARKINGS

Please refer MARKINGS section of Descriptive Report and Test Results for details.

Notes:

Products certified under Class C909801, C909881 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca

