



# Certificate / Certificat Zertifikat / 合格証

PFE 2001062 C001

*exida* hereby confirms that the:

## PF2200-FD Burner Control System

**Profire Energy, Inc.**

**Spruce Grove, AB - Canada**

Has been assessed per the relevant requirements of:

**IEC 61508 : 2010 Parts 1-7**

and meets requirements providing a level of integrity to:

**Systematic Capability: SC 2 (SIL 2 Capable)**

**Random Capability: Type B Element**

**SIL 2 @ HFT = 0; Route 1H**

**PFH/PFD<sub>avg</sub> and Architecture Constraints  
must be verified for each application**

### Safety Function:

The PF2200-FD monitors and controls a forced-draft burner using a pre-defined operating sequence. The PF2200-FD also monitors up to two independent pilot flame statuses and other interlock signals, and transitions to Safety Shutdown (Lockout) if conditions are judged to be unsafe.

### Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.

The manufacturer  
may use the mark:



Revision 1.0 March 31, 2020


Surveillance Audit Due  
April 1, 2023



ISO/IEC 17065  
PRODUCT CERTIFICATION BODY  
#1004



  
Evaluating Assessor

  
Certifying Assessor

PFE 20-01-062 C001

**Systematic Capability: SC 2 (SIL 2 Capable)**

**Random Capability: Type B Element**

**SIL 2 @ HFT = 0; Route 1H**

**PFH/PFD<sub>avg</sub> and Architecture Constraints  
must be verified for each application**

**Systematic Capability:**

The Product has met manufacturer design process requirements of Safety Integrity Level (SIL) 2. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

**Random Capability:**

The SIL limit imposed by the Architectural Constraints must be met for each element.

**IEC 61508 Failure Rates in FIT\***

Application/Device/Configuration	$\lambda_{SD}$	$\lambda_{SU}$	$\lambda_{DD}$	$\lambda_{DU}$
Common	347	57	146	51
RTD input channel	0	0	7	0.01
TC input channel	0	0	7	0.1
4-20mA/digital input channel	31	0.3	11	0.15
dry input channel	0.14	5	0	1
Ionization input channel	13.4	0.24	0	0.24
Ignition coil output channel	0	1	55	2
Powered output channel	50	0.3	16	0.16
Fan output	94	0.3	0	0

\* FIT = 1 failure / 10<sup>9</sup> hours

**SIL Verification:**

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD<sub>avg</sub> considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

**Assessment Report:** PFE 20-01-062 R002 V1R0

**Safety Manual:** PF2200-FD MANUAL Rev. 1.0



80 N Main St  
Sellersville, PA 18960

PF2200-FD Burner  
Control System