



Certificate of Compliance

Certificate: 70048876

Master Contract: 257037

Project: 70048876

Date Issued: October 8, 2015

Issued to: Profire Energy Inc
321 South 1250 West,, Suite 3
Lindon, UT 84042
USA
Attention: Mark Loveless

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Jelena Dzeletovic

Issued by: Jelena Dzeletovic

PRODUCTS

CLASS 9098 01 - MISCELLANEOUS - For Hazardous Locations
CLASS 9098 81 - MISCELLANEOUS - For Hazardous Locations - Certified to US Standards

[REDACTED]

[REDACTED]

[REDACTED]

[REDACTED]

[REDACTED]

Class I, Division 1, Groups B, C and D, T6, IP66, Type 4X;

Class I, Zone 1, AExd, IIB+H2, T6, Gb, IP66;



Certificate: 70048876

Master Contract: 257037

Project: 70048876

Date Issued: October 8, 2015

Ex d IIB+H2 T6 Gb, IP66

PF3102-00A Industrial Burner Control, input rated 36VDC, 1.0A, ambient temperature range -40°C to 60°C
Temperature Code T6 (85°C).

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 0-M1991 - General Requirements - Canadian Electrical Code Part II

CSA C22.2 No. 30-M1986:12 – Explosion-Proof Enclosures for Use in Class 1 Hazardous Locations

CSA Std C22.2 No. 142-M1987 - Process Control Equipment

CSA Std. C22.2 No. 94.2-07 (R2012) – Enclosures for electrical equipment, environmental considerations

CSA Std. C22.2 No. 60529:05 - Degrees of protection provided by enclosures (IP code)

ANSI/UL Std 50E, 1th Edition - Enclosures for Electrical Equipment, Environmental Considerations

ANSI/UL 1203 – 2013 – Standard for Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations

UL 429, 7th Ed. - 2013 – Standard for Safety, Electrically Operated Valves

CAN/CSA-C22.2 No. 60079-0:11 - Explosive Atmospheres - Part 0: Equipment - General requirements

CAN/CSA-C22.2 No. 60079-1:11 - Explosive Atmospheres - Part 1: Equipment protection by flameproof enclosures "d"

ANSI/IEC 60529 - Degrees of protection provided by enclosures (IP Code)

ANSI/ISA 60079-0:09 - Electrical Apparatus for Explosive Gas Atmospheres - Part 0: General Requirements

ANSI/ISA 60079-1:09 - Electrical Apparatus for Explosive Gas Atmospheres - Part 1: Flameproof Enclosures "d"